
sa-4 01.29.04

Color and Engraving Codes SG-4SN-

4-Scene with Off and Raise/Lower Wallstation



Description

- Used to select and adjust scenes in GRAFIK Eye Control Units.
- Large, rounded buttons are easy to use.
- Backlit buttons with optional engraving make it easy to find and operate the control in low light conditions.
- Optional button engraving is angled up to the eye for easy reading.
- Scene selection functionality can be selected in the field.
- Status LEDs indicate which scene is selected.
- Off button turns all lights off.
- Master raise/lower brightens or dims all lighting in the selected scene.
- Works with GRAFIK Eye 3000 and 4000 Series Control Units.
- Selects scenes in just one Control Unit or a group of up to eight Control Units.

Finish and Engraving Options

- Available with button engraving.
- Three engraving options are available: General Engraving, Standard Engraving, & Non-Standard Text Engraving. For more details, please refer to the seeTouch Ordering Guide (P/N 367-274) or visit the website at www.lutron.com/seetouch.

Field Selected Functionality

DIP Switch Settings 5 6	Scene selection buttons activate:
• • •	Scenes 1 to 4
+	Scenes 5 to 8
↓ ■ ↑	Scenes 9 to 12
i i	Scenes 13 to 16



DIP Switches 7-10 are set at the factory. Do not change switch 7, 8, or 9. Switch 10 controls the button backlight. Refer to product installation guide for more details.

ODECLEICATION CUDMITTAL

LUTRON SPECIFICATION SUBMITTAL		
Job Name:	Model Numbers:	
Job Number:		

sa-9 01.29.04

Specifications

Power

Low-voltage type Class 2 (PELV). Operating voltage:12/24 V Direct Current.

Key Design Features

- Field-changeable button and faceplate assemblies allow easy customization.
- Front accessible DIP switches allow change of function without removing the unit from the wall.
- Meets IEC 801-2. Tested to withstand 15kV electro-static discharge without damage or memory loss.
- Faceplate snaps on with no visible means of attachment.
- Available as an "insert" style control for multi-ganging.
- Can be ganged to share a common faceplate with NovaT*_® and Vareo_®
 Dimmers. To order new Wallplates for multi-ganging, specify "R3" openings
 in a Lutron NovaT* multi-gang FB (fins broken) Series model number.
- Use Button Replacement Kits to change color, button configuration, or engraving.
- Button Replacement Kits may also be used to convert between non-insert and insert configurations.

System Communications and Capacity

- Low-voltage type Class 2 (PELV) wiring connects Wallstations to Control Units and other components.
- Up to 8 Control Units and 16 total Wallstations and/or Control Interfaces may be connected for a total of 24 control points.

Terminals


Accept up to two #18 AWG (1.0mm²) typical.

Environment

32-104°F (0-40°C). Relative humidity less than 90% non-condensing.


Mounting

Typical backbox dimensions: 95mm (3.74") high, 55mm (2.17") wide, 70mm (2.75") deep.




Dimensions


Front View



Side View



Back View



Page 2

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:	
Job Number:		

sg-10 01.29.04

Color/Finish and Customizing Information

Color/Finish

Matte Finishes

White WH Ivory IV* ΒE Beige Gray GR* Brown BR Black BL

* GR, IV not currently backlighted

Metal Finishes

With Black Plastic Buttons (Standard)

Bright Brass BB Bright Chrome BC Bright Nickel BN Satin Brass SB Satin Chrome SC Satin Nickel SN Antique Brass QB Antique Bronze QΖ

Gloss Finishes

Available with Insert (I) style controls only. Ship with Claro® faceplates.

GWH White Light Almond **GLA**

Anodized Aluminum Finishes

Clear CLA Black BLA Brass **BRA**

Backlighting Notes:

Illuminated text (translucent text on buttons) is available for these colors: BL and BR (including all metal finishes).

Illuminated buttons (with black text on buttons) are available for these colors: WH, BE, GR, WH*, GLA*.

Multi-ganging

- Order Insert (I) style controls.
- To order new Wallplates for multi-ganging, specify "R3" openings in a Lutron NovaT*® multi-gang FB (fins broken) Series model number.

Examples:



Wallplate for 2 seeTouch Wallstations, Model # NT-R3-R3-FB-(color)




Wallplate for other Lutron controls and 2 seeTouch Wallstations, Model # NT-T8-R3-R3-FB-(color)

Note: New button inserts are not included with multi-ganging Wallplates.

Button Replacement Kits

Use Button Replacement Kits to change: colors, button configuration, engraving, between insert and non-insert versions.

Non-Insert Kit









Each Kit includes an adapter, button assembly, and wallplate

Insert Kit









SPECIFICATION SUBMITTAL

LUTRON. SPECIFICATION SUBMITTAL			Page 3
	Job Name:	Model Numbers:	
	Job Number:		

^{*} Insert (I) style controls only

sa-11 01.29.04

Wallstation Installation

DIP Switches

- Set DIP switches 1-4 to give the Wallstation a unique system address from 1 to 16.
- Set additional DIP switches (if any) to specify function as shown on the first page of the Wallstation's Specification Submittal.
- DIP switch 10 controls the button backlight.

Address	Address DIP Switch Settings			
	1	2	3	4
1	•	1	+	□
2	•	1	+	+
3	•	+	+	□
4	•	1	+	+
5	•	+	•	□
6	+	†	+	+
7	+	†	†	□
8	•	+	÷	+
9	+	†	•	□
10	+	†	•	+
11	+	1	†	□
12	+	1	†	+
13	+	+	•	■
14	+	+	•	V
15	+	+	+	.
16	+	+	+	†
Reserved for	or GRX	-PR	G, if p	oresent on link.

Low-voltage Class 2 (PELV) Wiring

- Use low-voltage Class 2 (PELV) wiring to daisy-chain Wallstations to Control Units and other components.
- Make connections inside the wallbox or in a switch/junction box with a maximum wire length of 8 feet (2.5m) from the link to the Wallstation.


When used with GRAFIK Eye 3000 Control Units

- Two #18 AWG (1.0mm²) conductors for common (terminal 1) and 12VDC (terminal 2). Ensure that the terminal 2 connection is wired correctly. Refer to GRAFIK Eye 3000 Series Specification Submittal.
- One shielded, twisted pair #18 AWG (1.0mm²) for data link (terminals 3 and 4).

When used with GRAFIK Eye 4000 Control Units

- Two #12 AWG (2.5mm²) conductors for common (terminal 1) and 24VFW (terminal 2). These won't fit in terminals. Connect as shown.
- One shielded, twisted pair #18 AWG (1.0mm²) for data link (terminals 3 and 4).
- Connect Drain/Shield as shown. Do not connect to Ground (Earth) or Wallstation. Connect the bare drain wires and cut off the outside shield.

Note: Use appropriate wire connecting devices as specified by local codes.



ELUTRON. SPECIFICATION SUBMITTAL

SI Edition 30DMITTAL		
Job Name:	Model Numbers:	
Job Number:		